

FIRE SAFETY CERTIFICATE

No.

Dated:

Certified that the ATRISH PUBLIC SCHOOL (name of the building or premises) at ROSHNABAD, HARIDWAR, 249403 (address) comprised of ZERO basement(s) and GROUND + 2 UPPER FLOORS (upper floors) owned/ occupied by ATRISH PUBLIC SCHOOL (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 20/06/2024 (date of inspection) in the presence of Mrs. MADHU TOMAR (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes XII (X/ XII) With effect from 27/06/2024 for a period of 01 year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Fire Extinguisher ABC 5kg - 10 nos. CO2 4.5kg - 02 nos
2. Hose reel - 02 nos
3. Fire Alarm - 04 nos
4. Fire Pump SHP-1 water tower tank - 5000Ltr

Issued on 27-06-2024 (date of issue) at (place) by

*Strike out whichever is not applicable.

Signature with Seal: [Signature]

Name

Shri. Shishupal Singh

Designation

F.S.O

Name & Address of Department/ Office:

Fire Station mayapur
Haridwar

To

ATRISH PUBLIC SCHOOL
ROSHNABAD, HARIDWAR, 249403
(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to
(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.